




RESTORE-LITE®
TEMPORARY POWER RESTORATION

Installation and Operation of Cord Sets

The cord set is designed to connect two RESTORE-LITE® units to the power terminal and neutral. **This unit is for use with part number P80070 and P80071 only.**



To RESTORE-LITE® Units — Follow Color Code

CORD SET WITH TANDEM CONNECTOR STYLE

300 AMP CONNECTORS
P80044

To House Meter



To House "Neutral"/ Pig Tail



1 ATTACH EXTERNAL CORD TO RESTORE-LITE® CASE.

Twist lock connection

2 ATTACH CONDUCTOR AND TWIST TO SECURE.

Pig tail provided if required.

3 READY FOR USE.

Twist to lock Twist to unlock



4 FINISHING

When finished, disconnect all cord sets from RESTORE-LITE® unit and store the cords in storage bag.

Failure to remove cord sets before transporting unit can result in damage to the cord set and can cause failure.



Always use in accordance with your company practices and procedures.



Visit sncmfg.com to learn more about RESTORE-LITE® or scan the QR code with your mobile device to be taken directly to our website.



www.sncmfg.com | 800-558-3325 | info@sncmfg.com

T0599
05/23