



RESTORE-LITE®
TEMPORARY POWER RESTORATION

Installation and Operation of Cord Sets

The cord set is designed to connect the RESTORE-LITE® unit to the power terminal and neutral.

To RESTORE-
LITE® Unit —
Follow
Color Code



To House
Terminal
Hook Up

300 AMP CORD SET WITH CRIMPED LUGS

COMPATIBLE WITH RESTORE-
LITE® UNITS P80070, P80071
P80072, P80079, AND P80079E

- P80135 (8 FT. CORD)

COMPATIBLE WITH RESTORE-
LITE® UNIT P80100

- P80106 (8 FT. CORD)
- P80123 (9 FT. CORD)




1 ATTACH EXTERNAL CORD TO RESTORE-LITE® CASE.

Twist lock connection

2 ATTACH CONDUCTOR AND TWIST TO SECURE.

3 READY FOR USE.

Twist to lock Twist to unlock



4 FINISHING

When finished, disconnect all cord sets from RESTORE-LITE® unit and store the cords in storage bag.

Failure to remove cord sets before transporting unit can result in damage to the cord set and can cause failure.



Always use in accordance with your company practices and procedures.



Visit sncmfg.com to learn more about RESTORE-LITE® or scan the QR code with your mobile device to be taken directly to our website.



www.sncmfg.com | 800-558-3325 | info@sncmfg.com

T0600
05/23