



RESTORE-LITE[®]
TEMPORARY POWER RESTORATION

Installation and Operation of Lever Bypass Adapter

The Lever Bypass Adapter is designed to connect the RESTORE-LITE[®] meter head cord set to a 320-amp meter box.



LEVER BYPASS ADAPTER

• P80069

To House Meter

To Ground
Lug in House
Meter Box

1 REMOVE COVER OF SERVICE PANEL

2 OPERATE LEVER BYPASS AND REMOVE THE METER



↑ Open
Lever Bypass
↓ Close

3 INSTALL ADAPTER AND CLOSE BYPASS



4 MAKE NEUTRAL CONNECTION FROM ADAPTER TO GROUND/NEUTRAL LUG



5 REPLACE SERVICE PANEL COVER



6 MAKE NEUTRAL CONNECTION BETWEEN RESTORE-LITE® METER HEAD CORD SET AND ADAPTER LUG





7 **PLUG RESTORE-LITE® METER HEAD CORD SET INTO THE ADAPTER**



8 **INSTALL METER SECURITY RING BETWEEN ADAPTER AND RESTORE-LITE® METER HEAD CORD SET**

Engage latches on base of meter head cord set into security ring

Always use in accordance with your company practices and procedures.



Visit sncmfg.com to learn more about RESTORE-LITE® or scan the QR code with your mobile device to be taken directly to our website.

